

Flags

T Out of Control	A Arithmetic Error (math calculation error)	t Out of Control (Partial)	S Site Visit
s Site Activity	> Some Data Missing	+ Max Exceeded	- Min Exceeded
< Logger Invalid	? Suspect	a Audit	B Bad Status
C Calibration	c Ceiling Limit	D Channel Disabled	E Edited
e Site Malfunction	f Floor Limit	H High-High Alarm	h High Alarm
I Invalidated By Edit	J High Rate of Change Exceeded	L Low-Low Alarm	I Low Alarm
M Maintenance	m Marked Maint by edit	O Overrange	o Other
P Power Failure	p Precision Check	Q Quality Assured	R Rate of Change Exceeded
V Dig Info#1	W Dig Info#2	X Dig Info#3	Y Dig Info#4
Z Dig Info#5	z Zero Adjusted	F Boiler Offline	j Low Rate of Change Exceeded